

BUILDING SAFETY CERTIFICATENo. HLM-621

Dated : 08.12.2025

Certified that the existing building Gyanjyoti Public School (name of the building or premises) at Vill – Chandua, P.O. Kanchrapara, P.S. Bizpur, Sub-Division – Barrackpore, Dist. North 24 Parganas – 743145, West Bengal (address) comprised of Not Applicable basement(s) and G+2 (upper floors) owned/occupied by Gyanjyoti Public School (Name of the Institution) have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of PWD, Halisahar Municipality (Name of Department/ Govt.) on 08.12.2025 (date of inspection) in the presence of Smt. Sarmistha Bhowmik Roy, Secretary (name and addresses of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy upto classes XII (X / XII) with effect from 08.12.2025 for a period of 3 (Three) years in accordance with rule and subject to compliance of the specific conditions as appended.

1. The Certificate is hereby issued on the basis of documents submitted by applicant i.e. structural details.
2. Building has been done as per vetted drawing design.
3. This certificate is issued subject to the condition that the applicant shall take all the necessary safety measures as required under various Act/Rules from time to time.
4. The Building Completion certificate is issued by Panchayet Pradhan, Kampa-Chakla Gram Panchayet 02.02.2022.

Issued on 08.12.2025 at Halisahar Municipality by

* Strike out whichever is not applicable.

Signature with Seal : _____

Basudeb Biswas
08/12/2025
Assistant Engineer
Halisahar Municipality

Name : MR. BASUDEB BISWAS

Designation : ASSISTANT ENGINEER

Name & Address of Department/ Office : HALISAHAR MUNICIPALITY

(Assistant Engineer & above officer of concerned Govt. Department only)

Note: This certificate should be signed / issued by Assistant Engineer & above officer of concerned Govt. Department only

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

FIRE SAFETY CERTIFICATENo. FSC/983Dated : 14.07.2025

Certified that the Gyanjyoti Public School (name of the building or Premises) at Vill – Chandua, P.O. Kanchrapara, P.S. Bizpur, Sub-Division – Barrackpore, Dist. North 24 Parganas – 743145, West Bengal (address) comprised of Ground floor..... basement(s) and First & Second Floor..... (upper floors) owned/occupied by Gyanjyoti Public School (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 02.07.2025 (date of inspection) in the presence of Smt. Sarmistha Bhowmik Roy, Secretary, 53, Ghatak Road, P.O. Kanchrapara, P.S. Bizpur, Dist. North 24 Parganas, PIN – 743145, West Bengal (name and addresses of the Manager/ Secretary or his representative) and that the building/ Premises is fit for occupancy upto classes XII..... (X/ XII) With effect from 14.07.2025..... for a period of 3 (Three)..... year in accordance with rule and subject to compliance of specific conditions as appended :-

1. Fire pump installed and good working condition .
2. Sprinkler System installed .
3. Section System installed .
- 4.

Issued on 14.07.2025 (date of issue) at North 24 Parganas Div. (place) by

* Strike out whichever is not applicable.

Sd/- 14.07.25
Divisional Fire Officer
North 24 Parganas Division

Signature with Seal : _____

Name : Sonoy Bag .

Designation : Divisional Fire Officer

Name & Address of Department/ Office : _____

To
The Secretary,
Gyanjyoti Public School,
Vill – Chandua, P.O. Kanchrapara,
P.S. Bizpur, Sub-Division – Barrackpore,
Dist. North 24 Parganas – 743145, West Bengal.
(Name & Address of the Institution)

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to _____
_____ (reasons to be recorded)

(Name and designation of the authorized signatory)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

MANGAL PANDAY WTP WATER TESTING LABORATORY

OFFICE OF THE EXECUTIVE ENGINEER,
NORTH 24 PARGANAS WATER SUPPLY DIVISION-I,
P.H.E. DTE.

Laboratory Address: Near Airport Area, Barrackpore, West Bengal, PIN-743144.
Contact No. 033 – 2594 7946. Email id. labdata.mpwtl@gmail.com



TEST REPORT

ULR NO.	TCI24412500000482F	Sample ID	MP/25/12/461	Reporting Date	I9-12-2025	
Issued to	GYANJYOTI PUBLIC SCHOOL					
Sample Source	VILL- CHANDUA, P.O. - KANCHRAPARA, BESIDE BARRACKPORE-KALYANI EXPRESSWAY, P.S. - BIZPUR, DIST. - NORTH 24 PARGANAS - 743145, WEST BENGAL		Collected by	Customer		
Memo Ref	GPS/060/25-26			Date	I0-12-2025	
Sample particulars	Acidified Sample	250 ml	Non-acidified sample	500 ml	Type of Sample	DRINKING WATER
Date of receive	I2-12-2025					
Date of Starting of Analysis	I3-12-2025		Date of Completion of Analysis		I8-12-2025	

N.B: Sample tested as received

We hereby certify that the following sample submitted to the laboratory has been analyzed with the following results:

ANALYSIS OF RESULTS

Sl. No.	Test Parameters	Unit	Test Methods	Recommended Drinking Water Quality as per IS 10500 : 2012 (Second Revision)		Results	Remarks
				Requirement (Acceptable Limit)	Permissible Limit in the absence of alternate Source		
1	pH	—	IS 3025 (Pt.11) : 2022, Electrometric method	6.5-8.5	6.5-8.5	7.72 at 25.3°C	
2	Total dissolved solids	mg/L	IS 3025 (Pt.16) : 2023, Gravimetric Method	500	2000	413	
3	Total Iron	mg/L	IS 3025 (Pt.53) : 2003, RA 2019, I-10 Phenanthroline Method	1	No Relaxation	<0.1	
4	Turbidity	NTU	IS 3025 (Pt.10) : 2023, Nephelometric Turbidity Meter	1	5	1.19	
5	Chloride	mg/L	IS 3025(Pt.32) : 1988,RA 2019, Argentometric Method	250	1000	21.21	
6	Alkalinity	mg/L	IS 3025 (Pt.23) : 2023, Indicator Method	200	600	332	
7	Total Hardness	mg/L	IS 3025 (Part 2I) : 2009, RA 2019, EDTA Titrimetric Method	200	600	364	
8	Total Arsenic	mg/L	IS : 3025 (Pt.37) 2022 Silver Diethyl Dithiocarbamate method	0.01	No Relaxation	<0.01	

Reviewed By:

Name: Swarup Mukhopadhyay

Designation: Chemist

Mr. Aniruddha Gooa
Technical Manager
Authorised Signatory

Mangal Panday WTP Water Testing Laboratory

** End of Report **

- The Result Relate only to the Item(s) Tested.
- The Test Report cannot be reproduced except in full, Without the Permission of Executive Engineer, North 24 Parganas Water Supply Div – I or Quality Manager.
- Sample not drawn by us.

MANGAL PANDAY WTP WATER TESTING LABORATORY

OFFICE OF THE EXECUTIVE ENGINEER,
NORTH 24 PARGANAS WATER SUPPLY DIVISION-I,
P.H.E. DTE.

Laboratory Address: Near Airport Area, Barrackpore, West Bengal, PIN-743144.

Contact No. 033 – 2594 7946.

Email id. labdata.mpwtl@gmail.com

TEST REPORT

ULR NO.	NA	Sample ID	MP/25/12/461	Reporting Date	19-12-2025	
Issued to	GYANJYOTI PUBLIC SCHOOL					
Sample Source	VILL- CHANDUA, P.O. - KANCHRAPARA, BESIDE BARRACKPORE-KALYANI EXPRESSWAY, P.S. - BIZPUR, DIST. - NORTH 24 PARGANAS - 743145, WEST BENGAL		Collected by	Customer		
Memo Ref	GPS/060/25-26			Date	10-12-2025	
Sample particulars	Acidified Sample	250 ml	Non-acidified sample	500 ml	Type of Sample	DRINKING WATER
Date of receive	12-12-2025					
Date of Starting of Analysis	13-12-2025		Date of Completion of Analysis		18-12-2025	

ANALYSIS OF RESULTS

Sl. No.	Test Parameters	Unit	Test Methods	Recommended Drinking Water Quality as per IS 10500 : 2012 (Second Revision)		Results	Remarks
				Requirement (Acceptable Limit)	Permissible Limit in the absence of alternate Source		
A1	Salinity	ppt	Electrometric	-	-	0.3	
A2	Conductivity	µS/cm	Electrometric	-	-	687	
A3	Residual Free Chlorine	mg/L	Colorimetric, DPD, with Colour-Disk Comparator Method	0.1	2	<0.1	
A4	Nitrate	mg/L	Spectrophotometric Method	45	No relaxation	2.1	
A5	Fluoride	mg/L	Spectrophotometric Method	1	1.5	-	
Organisms				Guidelines		Results	Remarks
A6	All water intended for drinking: E.coli or Thermotolerant Coliform Bacteria			Must not be detectable in any 100 ml sample		Not Detected	

Reviewed By:

Name: Swarup Mukhopadhyay

Designation: Chemist




Mr. Aniruddha Goen
Technical Manager
Authorised Signatory

Mangal Panday WTP Water Testing Laboratory